


DN (mm/inch)	L MIN (inch)	L MAX (inch)	Threaded Rods (inch)	No. Rods (pcs)	A (inch)	B (inch)
300/12"	11.02	16.14	7/8	4	22.44	3.15
350/14"	11.02	16.14	1	4	22.44	3.15
400/16"	11.02	16.14	1	4	22.44	3.15
450/18"	13.78	18.90	1 1/8	4	26.77	3.94
500/20"	13.78	18.90	1 1/8	4	26.77	3.94
600/24"	13.78	18.90	1 1/4	4	26.77	3.94

- 1) Hyjoint 2001 meets or exceeds all specifications of AWWA Standard C219.
- 2) Center Ring – ASTM A 53 Grade A steel.
- 3) End Rings – ASTM A 795 steel.
- 4) Gaskets – EPDM compounded for water and sewerage, meets NSF 61 requirements.
- 5) Bolts and Nuts on the End Ring – Type 304 stainless steel.  
Rolled thread and anti galling coating.
- 6) Bridge – Type 304 stainless steel.
- 7) Coating – 100% Fusion bonded epoxy for enhanced corrosion protection.  
Average thickness 14 Mil.
- 8) G = Min. Pipe Insertion of 1.75 inch
- 9) Working Pressure : 175 PSI
- 10) Flange – meets AWWA class D.

				Part Name: DISMANTLING JOINT with FLANGE AWWA-D		
Material		Weight		Note		
				Day	Name	Catalog No.
				Drawn	07.10.07 S.LORA	
				Check		Drawing No.
Edition	Change	Day	Name	Appr		811-56
						Scale